

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0785:154 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Wheelock, 273 Branchport Ave., Long Branch NJ 07740
Contact: Luy Nguyen (732) 222-6880 Fax (732) 222-5607

DESIGN: Models RSSWP-2475W synchronous or non-synchronous strobe light. Model may be followed by two alpha or numeric characters indicating lettering and color, followed by W for wall mount. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 16-33 VDC
Flash rate: 60 flashes/min.
Candela: 75 cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Model can be used outdoors when used with WPSBB back box only.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a strobe light for use with separately listed electrically compatible fire alarm control units. For indoor or outdoor use. Intended for wall mount only.

For synchronized strobes, Models SM-12/24, SMX-12/24 Sync Modules, DSM-12/24 or DSMX-12/24 Duel Sync Modules (CSFM Listing No. 7300-0785:1323) or power supply PS-12/24-8 (CSFM Listing No. 7315-0785:149) must be used.

NOTE: Not suitable for hearing impaired application.

01-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager